

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No: 18/2025

Dated: 16-05-2025

It is certified that an inspection team headed by **Assistant Engineer** (Name of Officers with designation) from **Construction Division, UK Pey Jal Nigam, Haridwar** inspected the **The Sanskar Velly Academy, Rawali Mehdood District-Haridwar (Uttarakhand) 249402** (Name & Address of the school) on 16-05-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 605/UJS/DLWQTM/2025-26 dated 10-05-2025 of **Jal Kal Abhiyanta, Uttarakhand Jal Sansthan, Haridwar** (PHED Lab) certified that the **The Sanskar Velly Academy, Rawali Mehdood District-Haridwar (Uttarakhand) 249402** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal:
 Name **ASSISTANT ENGINEER**
 Designation **CONSTRUCTION DIVISION**
 Name & Address of the Office / Department **UK PEY JAL NIGAM, HARIDWAR**

To,
**The Sanskar Velly Academy,
 Rawali Mehdood District-Haridwar (Uttarakhand) 249402**
 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Surendra
MANAGER
THE SANSKAR VELLY ACADEMY
 Rawali Mehdood (Haridwar)

Chawla
PRINCIPAL
THE SANSKAR VELLY ACADEMY
 Rawali Mehdood (Haridwar)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
 Ph (O): 0134-226360, E-mail: eeujs@yahoomail.com

TEST REPORT

Name and Address of Organization/ Customer	Rawali Mehdood Minakshipuram, Pumping Payjal Yojna Tubewell			
Test Report ID	605/UJS/DLWQTM/2025-26		Reporting Date	10/05/2025
Product Description	Drinking Water		Sample Location	Rawali Mehdood Minakshipuram
Reference Sample Identification:	DLWQTM/UJS/2025-605		Sample Collected by	Customer
Date of Start of Analysis:	08/05/2025			
Date of End of Analysis:	09/05/2025			
Date and Time of Sample Received:	08/05/2025 & 03:00 PM.			

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	6.99	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	320	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.79	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	204	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	232	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	57.6	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	17	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	21.38	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	5	5	15
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received.
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

(Er. Rakesh Chandra Bamrara)

Lab Incharge

जल कल अभियन्ता

उत्तराखण्ड जल संस्थान

हिन्दूर

MANAGER
THE SANSKAR VELLY ACADEMY
 Rawali Mehdood (Haridwar)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer		Rawali Mehdood Minakshipuram, Pumping Payjal Yojna Tubewell					
Test Report ID		605/UJS/DLWQTM/2025-26	Reporting Date	10/05/2025			
Product Description		Drinking Water	Sample Location	Rawali Mehdood Minakshipuram			
Reference Sample Identification:		DLWQTM/2025-605					
Date of Start of Analysis:		08/05/2025					
Date of End of Analysis:		09/05/2025					
Date and Time of Sample Received:		08/05/2025 & 03:00 PM.					
SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source		
1	Residual Free Chlorine, mg/L Min	APHA 23rd Ed.-4500- Cl-G	0.4	0.2	1.0		
4.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent		
5	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent		

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report ****

(Er. Rakesh Chandra Bamrara)

Lab Incharge

जल कल अभियन्ता

कल्पराज्य जल संरक्षण

हरिद्वार

PRINCIPAL

THE SANSKAR VELLY ACADEMY
Rawali Mehdood (Haridwar)

MANAGER
THE SANSKAR VELLY ACADEMY
Rawali Mehdood (Haridwar)